



Life Science Laboratories, Inc.

Genesee Valley School
1 Jaguar Drive
Belmont, NY 14813

Phone: (585) 268-7900
FAX: (585) 268-5810

Laboratory Analysis Report

Prepared For

Genesee Valley School

LSL Project ID: 1701633

Receive Date/Time: 02/03/17 10:32

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248
PA DEP #68-2556

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 728-3320
Fax (585) 728-2711
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by: LaDonna Kibler
LaDonna Kibler, Quality Assurance

Date: 2/16/17

- - LABORATORY ANALYSIS REPORT - -

Genesee Valley School Belmont, NY

Sample ID: Genesee Valley School **LSL Sample ID:** 1701633-001
Location: 029/HS Cafe DF
Sampled: 02/03/17 7:05 **Sampled By:** CC
Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8 Metals Please refer to the next page			EPA 200.2			MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1701633-Genesee Valley School
Location:
Matrix: PWS

Client Sample ID: 029 / HS CAFE DF

Lab ID: K1702081-001A
Collection Date: 02/03/17 7:05
Date Received: 02/03/17 10:32

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	< 0.0010	mg/L	02/14/17 12:27

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

- - LABORATORY ANALYSIS REPORT - -

Genesee Valley School Belmont, NY

Sample ID:	Genesee Valley School	LSL Sample ID:	1701633-002
Location:	060/2120 Fac. Sink		
Sampled:	02/03/17 7:10	Sampled By:	CC
Sample Matrix:	PWS		

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8 Metals			EPA 200.2			
Please refer to the next page						MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1701633-Genesee Valley School
Location:
Matrix: PWS

Client Sample ID: 060 / 2120 FAC Sink

Lab ID: K1702081-002A
Collection Date: 02/03/17 7:10
Date Received: 02/03/17 10:32

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	< 0.0010	mg/L	02/14/17 12:30

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

- - LABORATORY ANALYSIS REPORT - -

Genesee Valley School Belmont, NY

Sample ID: Genesee Valley School LSL Sample ID: 1701633-003
Location: 063/2268 Cr. Sink
Sampled: 02/03/17 7:22 Sampled By: CC
Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8 Metals Please refer to the next page			EPA 200.2			MT



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1701633-Genesee Valley School
Location:
Matrix: PWS

Client Sample ID: 063 / 2268 CR SINK

Lab ID: K1702081-003A
Collection Date: 02/03/17 7:22
Date Received: 02/03/17 10:32

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0011	mg/L	02/14/17 12:42

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1701633-Genesee Valley School
Location:
Matrix: PWS

Client Sample ID: 076 / 2260 DF
Lab ID: K1702081-004A
Collection Date: 02/03/17 7:25
Date Received: 02/03/17 10:32

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	< 0.0010	mg/L	02/14/17 12:46

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

- - LABORATORY ANALYSIS REPORT - -

Genesee Valley School Belmont, NY

Sample ID: Genesee Valley School LSL Sample ID: 1701633-005
Location: 112/1261 Cr. Sink
Sampled: 02/03/17 7:28 Sampled By: CC
Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
-------------------	--------	-------	-------------	-----------	----------------------	------------------

(1) EPA 200.8 Metals

EPA 200.2

Please refer to the next page

MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1701633-Genesee Valley School
Location:
Matrix: PWS

Client Sample ID: 112/1261 CR SINK

Lab ID: K1702081-005A
Collection Date: 02/03/17 7:28
Date Received: 02/03/17 10:32

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	< 0.0010	mg/L	02/14/17 12:50

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

Life Science Laboratories, Inc.

Sample Receipt Checklist

LSL LIMS

Project ID	1701633	Client ID:	Invoiced_Government		
Shipment Number	1	SRC Completed By:	jms01	Date:	2/7/2017 8:50:22 AM
COC Date/Time	Received By	Carrier	ShippingID		
2/3/2017 10:32:00 AM	ds02	Hand Delivered			
Shipping container/cooler in good condition?	Yes	Sample containers intact?	Yes		
Custody seal intact on shipping container/cooler?	N/A	Sufficient sample volume for indicated test?	Yes		
Custody seals intact on sample bottles?	N/A	All samples received within holding time?	Yes		
Chain of Custody present?	Yes	Container/Temp Blank temperature in compliance?	Yes		
COC signed when relinquished and received?	Yes	Water - VOA vials have zero headspace?	N/A		
COC agrees with sample labels?	Yes	Water - pH acceptable upon receipt?	N/A		
Samples in proper containers/bottles?	Yes	Water - HNO3 added to unpreserved metal sample(s) to a pH of <2?	Yes		

Comments:

Corrective Action:

Reviewed By:

JK, 2/16/17

